

25 AND 30-YEAR WARRANTY REQUIREMENTS

	25-Year NDL	30-Year NDL
Approved Membranes		
Duro-Last®	Yes, minimum of 60 mil nominal	N/A
Duro-Tuff®	Yes, minimum of 60 mil nominal	Yes, minimum of 80 mil nominal
Duro-Fleece®	Yes, minimum of 60 mil nominal	Yes, minimum of 80 mil nominal
Duro-Fleece Plus®	Yes, minimum of 60 mil nominal	N/A
Duro-Last EV	Yes, minimum of 60 mil nominal	N/A
Parapet and Flashings	Yes, minimum of 60 mil nominal	Yes, minimum of 60 mil nominal
Other Criteria		
Cover Board ***	Yes	Yes
Vapor Barrier	When required by a design professional	When required by a design professional
Consequential Damages	No	No
Transfer of Warranty	Yes, inspection and fee	Yes, inspection and fee
Contractor Level	Platinum, Elite or Master	Platinum, Elite or Master
New Construction or Tear Off	Yes	Yes
Recover	No	No
Base Warranty Cost	\$0.23/sq. ft.	\$0.33/sq. ft.
Hail Coverage	No	No
High Wind	Yes	Yes
High Wind Additional Costs		
55 – 72 mph	No cost	No cost
73 – 80 mph	\$0.10/sq. ft.	\$0.12/sq. ft.
81 – 90 mph	\$0.12/sq. ft.	\$0.14/sq. ft.
91 – 100 mph	\$0.14/sq. ft.	\$0.16/sq. ft.
101 – 110 mph	\$0.16/sq. ft.	\$0.18/sq. ft.
111 – 120 mph	\$0.18/sq. ft.	\$0.20/sq. ft.

Requirements continued on page 2.

Requirements continued from page 1.

	25-Year NDL	30-Year NDL		
Approved Deck Types for Mechanically Fastened Systems *				
Wood (5/8-inch Plywood or 1-inch Plank minimum)	Yes, pull value of 450 lbs or greater	Yes, pull value of 450 lbs or greater		
Steel	Yes	Yes		
Concrete	Yes	Yes		
Lightweight Insulating Concrete	No	No		
Gypsum	No	No		
Cementitious Wood Fiber	No	No		
Metal Standing Seam	Yes, purlin attachment only (plates/fasteners or Duro-Bond®)	Yes, purlin attachment only (plates/fasteners or Duro-Bond®)		
Approved Deck Types for Adhered Systems **				
	Mechanically fastened Insulation/cover board (any layers)	Adhered Insulation/cover board (all layers)	Mechanically fastened Insulation/cover board (any layers)	Adhered Insulation/cover board (all layers)
Wood (5/8-inch Plywood or 1-inch Plank minimum)	Yes, pull value of 450 lbs or greater	Yes	Yes, pull value of 450 lbs or greater	Yes
Steel	Yes	Yes	Yes	Yes
Concrete	Yes	Yes	Yes	Yes
Lightweight Insulating Concrete	No	Yes	No	Yes
Gypsum	No	Yes	No	Yes
Cementitious Wood Fiber	No	Yes	No	Yes
Metal Standing Seam	Yes	Yes	Yes	Yes
Allowable Adhesives				
SB IV Adhesive (bareback membranes)	Yes		No	
WB II Adhesive (Duro-Fleece membranes)	Yes		No	
Duro-Fleece CR-20 Membrane Adhesive (splatter pattern) (Duro-Fleece membranes)	Yes		Yes	
Duro-Grip® CR-20 (ribbon pattern) (insulations and cover boards)	Yes		Yes	
Duro-Grip Millenium Weather-Tite® Hurricane Force® PG-1 (ribbon pattern) (insulations and cover boards)	Yes		Yes	
Duro-Grip Millenium Weather-Tite® One Step™ (ribbon pattern) (insulations and cover boards)	Yes		Yes	

* Maximum tab spacing for mechanically fastened systems is 60 inches on center.

** Any roll size may be used for adhered systems and Duro-Bond systems.

*** Approved cover boards are DensDeck®, DensDeck Prime, Securock Gypsum-Fiber, Securock Glass-Mat, DEXcell® Glass Mat, DEXcell FA Glass Mat, DEXcell Cement, and Duro-Guard® ISO HD.

Note: All edge metal must be purchased from Exceptional® Metals and all other materials must be purchased from Duro-Last.